



2016 Drought Contingency Plan Summary

Stage 1
Triggers: Supply drops below 75% (25% depleted); or demand reaches 80% delivery capacity for 3 consecutive days
Response: Not to exceed two-days-per-week outdoor irrigation schedule (mandatory)
Water Use Reduction Goal: 5%
Stage 2
Triggers: Supply drops below 60% (40% depleted); or demand reaches 85% delivery capacity for 3 consecutive days
Response: Not to exceed one-day-per-week outdoor irrigation schedule (mandatory)
Water Use Reduction Goal: 10%
Stage 3
Triggers: Supply drops below 45% (55% depleted); or demand reaches 90% delivery capacity for 3 consecutive days
Response: Outdoor Irrigation Prohibited
Water Use Reduction Goal: 20%